



NOT1: In the relay system, the information that the curtains are open and closed is not displayed on the monitor or mobile screen.

NOT2: If it is desired to control the lit switches in the rooms while the curtains are going up and down from the monitor screen, the curtain motors may be damaged.

NOT3: The control ends of the curtain motors in the rooms of the house must be pulled into the system room where the rail-type relays are located.

